

RUSSIAN FEDERATION

application

to **CERTIFICATE OF CONFORMITY № C-SE.ПБ34.B.00998**

(obligatory certification)

TP 0251779

(account number of sheet)

Information about national standards (set of rules), applicable to voluntary basis for compliance with the requirements of technical regulation

Designation of national standard or set of rules	Description of national standard or set of rules	Confirmable requirements of national standards or set of rules
ГОСТ ¹ 30402-96	Building materials. Inflammability testing method.	Degree of inflammability – B2 (moderate inflammable)
ГОСТ 12.1.044-89*	Fire and explosion hazard of substances and materials. Nomenclature of measure and estimation methods.	Coefficient of smoke generation – D2 (with moderate smoke-forming capability, p. 2.14)
ГОСТ 12.1.044-89*	Fire and explosion hazard of substances and materials. Nomenclature of measure and estimation methods.	Toxicity equivalent – T2 (moderate hazardous, p.2.16)
ГОСТ 30244-94	Building materials. Combustibility testing methods.	Degree of combustibility – G2 (moderate combustible)
ГОСТ 12.1.044-89*	Fire and explosion hazard of substances and materials. Nomenclature of measure and estimation methods.	Hardly-combustible, p.4.3

Director
(deputy director)
of certification body
signature, initials, surname

V. Gubin

Expert (experts)
signature, initials, surname

A. Topchy

¹ ГОСТ – State Standard (translator's note)